

## DRINKING WATER SYSTEM ANNUAL REPORT

**Reporting Period:** January 1<sup>st</sup> to December 31<sup>st</sup>, 2024 (year)

**Water System** District of Kent Water System

**Water System Owner** District of Kent

**Primary Contact Name (Operator or Manager)** Steven Nuttall

**Phone Number (Operator or Manager)** 604-796-9145

**E-mail (Operator or Manager)** snuttall@kentbc.ca

## DESCRIBE YOUR WATER SUPPLY SYSTEM

**What is the Source(s) of Raw Water?**

Deep Well       Shallow Well       Surface Water       Other

If other, specify details:

**Does the Drinking Water System have Primary Disinfection?**

Yes       No

Chlorination       Ultraviolet Light       Ozone       Other

If other, specify details:

**Does the Drinking Water System have Secondary Disinfection?**

Yes       No

Chlorination       Other

If other, specify details:

**Does the Drinking Water System have Filtration?**

Yes       No

Check all boxes that apply

Cartridge Filter(s)       Carbon Filter       Sand Filtration       Reverse Osmosis       Other

If other, specify details:

## PUBLIC REPORTING

**Emergency Response & Contingency Plan (ERCP)**

**Is your ERCP up to Date?**       Yes       No

**How do you Inform the System Users of the ERCP?**

Hand Delivered       Bulletin Board       Newspaper       Utility Bill Insert       Website

Other (specify details)

**Drinking Water System Annual Report****How do you Inform the System Users of the Annual Report?**

Hand Delivered       Bulletin Board       Newspaper       Utility Bill Insert       Website

Other (specify details)

**COMPLIANCE WITH OPERATING PERMIT**

List the conditions that have been placed on your Operating Permit (if you have conditions, these will be stated on your permit):

---



---



---

Are you in compliance with the conditions listed on your Operating Permit?  Yes  No  N/A

**BACTERIOLOGICAL TESTING AND DRINKING WATER PROTECTION REGULATION WATER QUALITY STANDARDS**

How many bacteriological samples were collected during this reporting period? 165

What is the minimum required sampling frequency for this system? (#samples/month) 8

Additional sampling details:

Was the minimum required sampling frequency achieved?  Yes  No

Comments:

Bacteriological summary attached to this report?  Yes  No

If no, how do the users of the system view the results?

**WATER QUALITY STANDARDS FOR POTABLE WATER**

Parameter:	Standard:	Did this system meet standard?	
Escherichia coli (for all samples)	No detectable <i>Escherichia coli</i> per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Total Coliform Bacteria (if only 1 sample collected in a 30 day period)	No detectable total coliform bacteria per 100ml	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Total Coliform Bacteria (if more than 1 sample collected in a 30 day period)	No more than 10% of samples contain total coliform bacteria, and No sample has more than 10 total coliform bacteria per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

If the system did not meet any of above Drinking Water Protection Regulation standards, record the results in the table below; attach additional sheets if necessary.

Date	TC/100ml	E.coli/100ml	Reason	Corrective Action
11-Nov-2024	1	0	Unknown	Flushed system and resampled

**CHEMICAL SAMPLING COMPLETED DURING THIS REPORTING PERIOD**

**Was any chemical sampling conducted during reporting period?**  Yes  No

**If no, when were the last chemical samples conducted for this system?**

(date)  Don't Know  Never

**If yes, did all water samples meet the Guidelines for Canadian Drinking Water Quality?**

Yes  No

**If any water samples did not meet the Guidelines for Canadian Drinking Water Quality, record the results in the table below; attach additional sheets if necessary.**

Parameter	Result	Corrective Action / Treatment / Comments

**ADDITIONAL TESTING**

**Does the system have analyzers for continuous monitoring?**  Yes  No

**If yes, check all boxes that apply:**

Chlorine  Turbidity  Other (details) pH and Temperature

**Are the results available on request?** no

**If any additional testing or sampling was conducted, record results in the table below; attach additional sheets if necessary.**

Additional Testing & Reason for Sampling	Corrective Action Taken

**WATER QUALITY COMPLAINTS**

**Were there any water quality complaints in this reporting period? (e.g. taste, odour, colour etc.)**  Yes  No

**If yes, complete the table below; attach additional sheets if necessary.**

Date	Water Quality Complaint	Corrective Action / Treatment

**OPERATIONAL PROBLEMS**

Were there any operational problems during this reporting period? (e.g. insufficient water supply, malfunction of disinfection equipment, line breaks, elevated turbidity etc.).  Yes  No

If yes, complete the table below; attach additional sheets if necessary.

Incident Date	Type of Operational Problem	Corrective Action Taken

**MAJOR UPGRADES/REPAIRS & EXPENSES**

Were there any major upgrades/repairs or any major costs incurred during this reporting period?  Yes  No

If yes, complete the table below; attach additional sheets if necessary.

Major Upgrades/Expenses	Details
Improvements required by DWO	
Additions/changes to system	
Purchase or install new equipment	
Equipment repair or replacement	
Annual maintenance of system	
Specialist report	
Other	

**FUTURE IMPROVEMENTS**

Are there any plans for future improvements?  Yes  No

If yes, complete the table below; attach additional sheets if necessary.

Future Upgrades or Improvements	Estimated Date of Completion

DATE COMPLETED: 24-Jun-2025	COMPLETED BY: Steven Nuttall
-----------------------------	------------------------------



**fraserhealth**

Better health.  
Best in health care.

January 25, 2025

*Water System Operators*

**Re: Metals in Drinking Water – “Flush” Message in Annual Reports**

---

Anytime the water in a particular faucet has not been used for six hours or longer, "flush" your cold-water pipes by running the water until you notice a change in temperature. *(This could take as little as five to thirty seconds if there has been recent heavy water use such as showering or toilet flushing. Otherwise, it could take two minutes or longer.)* The more time water has been sitting in your home's pipes, the more lead it may contain.

Use only water from the cold tap for drinking, cooking, and especially making baby formula. Hot water is likely to contain higher levels of lead.

The two actions recommended above are very important to the health of your family. They will probably be effective in reducing lead levels because most of the lead in household water usually comes from the plumbing in your house, not from the local water supply.

Conserving water is still important. Rather than just running the water down the drain you could use the water for things such as watering your plants.

If you have any questions, please contact our Drinking Water Program at 604-870-7903 or 1-866-749-7900.

Sincerely,

Alex Kwan  
Acting Manager, Drinking Water Program  
Fraser Health Authority  
[HPLand@fraserhealth.ca](mailto:HPLand@fraserhealth.ca)

**Analytical Report**

Bill To: District of Kent Waste Water  
 Box 70  
 1088 Tramner Road  
 Agassiz, BC, Canada  
 V0M 1A0  
 Attn: Accounts Payable  
 Sampled By:  
 Company:

Project ID:  
 Project Name:  
 Project Location:  
 LSD:  
 P.O.: 27281  
 Proj. Acct. code:

Lot ID: **1730182**  
 Control Number:  
 Date Received: May 7, 2024  
 Date Reported: May 13, 2024  
 Report Number: 3001367  
 Report Type: Final Report

**Reference Number** 1730182-1  
**Sample Date** May 07, 2024  
**Sample Time** 09:00  
**Sample Location**  
**Sample Description** Reservoir #1 / 9.6 °C  
**Sample Matrix** Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
<b>Metals Extractable</b>						
Aluminum	Extractable	mg/L	0.002	0.001	0.1 OG; 2.9 MAC	Below OG
Antimony	Extractable	mg/L	0.00010	0.00002	0.006	Below MAC
Arsenic	Extractable	mg/L	0.0025	0.0001	0.010	Below MAC
Barium	Extractable	mg/L	0.018	0.0001	2.0	Below MAC
Boron	Extractable	mg/L	0.017	0.002	5	Below MAC
Cadmium	Extractable	mg/L	<0.00001	0.00001	0.007	Below MAC
Chromium	Extractable	mg/L	<0.00005	0.00005	0.05	Below MAC
Copper	Extractable	mg/L	0.0009	0.0005	1 AO; 2 MAC	Below AO
Lead	Extractable	mg/L	0.00008	0.00001	0.005	Below MAC
Selenium	Extractable	mg/L	<0.0002	0.0002	0.05	Below MAC
Strontium	Extractable	mg/L	0.11	0.0001	7.0	Below MAC
Uranium	Extractable	mg/L	0.00026	0.00001	0.02	Below MAC
Vanadium	Extractable	mg/L	0.0013	0.00005		
Zinc	Extractable	mg/L	0.0023	0.0005	5.0	Below AO
<b>Microbiological Analysis</b>						
Total Coliforms	Enzyme Substrate Test	MPN/100 mL	<1.0	1.0	0 per 100 mL	Below MAC
Escherichia coli	Enzyme Substrate Test	MPN/100 mL	<1.0	1.0	0 per 100 mL	Below MAC
<b>Physical and Aggregate Properties</b>						
Colour	True	Colour units	<5	5		
Turbidity		NTU	<0.10	0.1	0.1/0.3/1.0 OG	
<b>Routine Water</b>						
pH			7.77	0.01	7.0-10.5	Within Range
pH - Holding Time			Exceeded			
Temp. of observed pH		°C	23.9			
Electrical Conductivity	at 25 °C	µS/cm	218	1		
Calcium	Extractable	mg/L	32	0.01		
Iron	Extractable	mg/L	<0.004	0.004	0.3	Below AO
Magnesium	Extractable	mg/L	5.9	0.02		
Manganese	Extractable	mg/L	0.003	0.001	0.02 AO; 0.12 MAC	Below AO
Potassium	Extractable	mg/L	1.5	0.04		
Silicon	Extractable	mg/L	6.5	0.005		
Sodium	Extractable	mg/L	2.8	0.1	200	Below AO
T-Alkalinity	as CaCO3	mg/L	97	5		
Chloride	Dissolved	mg/L	1.11	0.05	250	Below AO
Fluoride	Dissolved	mg/L	0.01	0.01	1.5	Below MAC
Nitrate - N	Dissolved	mg/L	0.28	0.01	10	Below MAC

**Analytical Report**


 Bill To: District of Kent Waste Water  
 Box 70  
 1088 Tramner Road  
 Agassiz, BC, Canada  
 V0M 1A0  
 Attn: Accounts Payable  
 Sampled By:  
 Company:

 Project ID:  
 Project Name:  
 Project Location:  
 LSD:  
 P.O.: 27281  
 Proj. Acct. code:

 Lot ID: **1730182**  
 Control Number:  
 Date Received: May 7, 2024  
 Date Reported: May 13, 2024  
 Report Number: 3001367  
 Report Type: Final Report

<b>Reference Number</b>	1730182-1
<b>Sample Date</b>	May 07, 2024
<b>Sample Time</b>	09:00
<b>Sample Location</b>	
<b>Sample Description</b>	Reservoir #1 / 9.6 °C
<b>Sample Matrix</b>	Drinking Water

Analyte	Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
<b>Routine Water - Continued</b>					
Nitrite - N	Dissolved mg/L	<0.01	0.01	1	Below MAC
Sulfate (SO4)	Dissolved mg/L	11.4	0.1	500	Below AO
Hardness	as CaCO3 (extractable) mg/L	104	1		
Total Dissolved Solids	Extractable mg/L	132	1	500	Below AO

 Approved by:   
 Rachel Eden, B. Sc.  
 Operations Manager

## Methodology and Notes

Bill To: District of Kent Waste Water Box 70 1088 Tramner Road Agassiz, BC, Canada V0M 1A0 Attn: Accounts Payable	Project ID: Project Name: Project Location: LSD: P.O.: 27281 Proj. Acct. code:	Lot ID: <b>1730182</b> Control Number: Date Received: May 7, 2024 Date Reported: May 13, 2024 Report Number: 3001367 Report Type: Final Report
Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Alk, pH, EC, Turb in water (BC)	APHA	* Alkalinity - Titration Method, 2320 B	May 9, 2024	Element Vancouver
Alk, pH, EC, Turb in water (BC)	APHA	* Conductivity, 2510 B	May 9, 2024	Element Vancouver
Alk, pH, EC, Turb in water (BC)	APHA	* pH - Electrometric Method, 4500-H+ B	May 9, 2024	Element Vancouver
Anions by IEC in water (VAN)	APHA	* Ion Chromatography with Chemical Suppression of Eluent Cond., 4110 B	May 8, 2024	Element Vancouver
Metals SemiTrace (Extractable) in water (VAN)	US EPA	* Metals & Trace Elements by ICP-AES, 6010C	May 8, 2024	Element Vancouver
Total and E-Coli - Colilert - DW (VAN)	APHA	Enzyme Substrate Test, APHA 9223 B	May 7, 2024	Element Vancouver
Trace Metals (extractable) in Water (VAN)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8	May 8, 2024	Element Vancouver
True Color in water (VAN)	APHA	* Spectrophotometric - Single Wavelength Method, 2120 C	May 9, 2024	Element Vancouver
Turbidity - Water (VAN)	APHA	* Turbidity - Nephelometric Method, 2130 B	May 8, 2024	Element Vancouver

\* Reference Method Modified

## References

APHA	Standard Methods for the Examination of Water and Wastewater
US EPA	US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description	Health Canada GCDWQ
Guideline Source	Guidelines for Canadian Drinking Water Quality, Health Canada, Sept 2020
Guideline Comments	MAC = Maximum Acceptable Concentration AO = Aesthetic Objective OG = Operational Guideline for Water Treatment Plants (does not apply to private groundwater wells). Refer to Health Canada for complete guidelines at <a href="http://www.hc-sc.gc.ca">www.hc-sc.gc.ca</a>

## Comments:

- May 13, 2024 - The analysis of water sample 1730182-1 is below Maximum Acceptable Concentrations for the chemical and bacteriological health related guidelines specified by the September 2022 Guidelines for Canadian Drinking Water Quality for the parameters tested.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

# Sample Range Report

Fraser Health Authority

**Facility Name:** District of Kent Water System

**Date Range:** Jan 1 2024 to Dec 31 2024

**Operator** Steve Nuttall  
Box 70

7170 Cheam Ave  
Agassiz, BC V0M 1A0

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Key Road Sampling Station,</u>				
	1-2-2024 10:00:00 AM	LT1	LT1	
	2-5-2024 9:55:00 AM	LT1	LT1	
	2-12-2024 10:45:00 AM	LT1	LT1	
	3-5-2024 9:20:00 AM	LT1	LT1	
	3-18-2024 9:55:00 AM	LT1	LT1	
	4-2-2024 10:00:00 AM	LT1	LT1	
	4-15-2024 10:05:00 AM	LT1	LT1	
	4-29-2024 9:35:00 AM	LT1	LT1	
	5-13-2024 9:50:00 AM	LT1	LT1	
	5-27-2024 9:35:00 AM	LT1	LT1	
	6-10-2024 9:50:00 AM	LT1	LT1	
	6-24-2024 11:15:00 AM	LT1	LT1	
	7-8-2024 9:30:00 AM	LT1	LT1	
	7-22-2024 9:50:00 AM	LT1	LT1	
	8-6-2024 9:50:00 AM	LT1	LT1	
	8-20-2024 8:40:00 AM	LT1	LT1	
	9-3-2024 9:25:00 AM	LT1	LT1	
	9-16-2024 8:30:00 AM	LT1	LT1	
	10-1-2024 10:00:00 AM	LT1	LT1	
	10-15-2024 9:30:00	LT1	LT1	

AM			
10-29-2024 9:05:00	LT1	LT1	
AM			
11-12-2024 11:10:00	LT1	LT1	
AM			
11-26-2024 11:20:00	LT1	LT1	
AM			
12-10-2024 9:50:00	<u>LT1</u>	<u>LT1</u>	
AM			
<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

McCaffrey Road  
Sampling Station.

1-8-2024 9:35:00	LT1	LT1	
AM			
2-20-2024 10:20:00	LT1	LT1	
AM			
2-26-2024 8:10:00	LT1	LT1	
AM			
3-11-2024 10:40:00	LT1	LT1	
AM			
3-25-2024 9:45:00	LT1	LT1	
AM			
4-8-2024 9:35:00	LT1	LT1	
AM			
4-23-2024 10:25:00	LT1	LT1	
AM			
5-7-2024 10:35:00	LT1	LT1	
AM			
5-21-2024 11:05:00	LT1	LT1	
AM			
6-3-2024 10:40:00	LT1	LT1	
AM			
6-17-2024 9:45:00	LT1	LT1	
AM			
7-15-2024 9:05:00	LT1	LT1	
AM			
7-29-2024 10:00:00	LT1	LT1	
AM			
8-13-2024 9:00:00	LT1	LT1	
AM			
8-26-2024 10:15:00	LT1	LT1	
AM			
9-9-2024 9:40:00	LT1	LT1	
AM			
9-23-2024 9:30:00	LT1	LT1	
AM			
10-7-2024 9:35:00	LT1	LT1	
AM			
10-22-2024 10:30:00	LT1	LT1	
AM			
11-5-2024 10:46:00	1	LT1	
AM			
11-19-2024 10:20:00	LT1	LT1	
AM			

12-2-2024 10:25:00 AM	LT1	LT1	
12-17-2024 9:50:00 AM	<u>LT1</u>	<u>LT1</u>	
<b>Total Positive:</b>	<b>1</b>	<b>0</b>	<b>0</b>

West Pioneer  
Sampling Station.

1-8-2024 11:00:00 AM	LT1	LT1	
2-12-2024 10:30:00 AM	LT1	LT1	
2-26-2024 8:20:00 AM	LT1	LT1	
3-11-2024 11:55:00 AM	LT1	LT1	
3-25-2024 11:05:00 AM	LT1	LT1	
4-23-2024 10:40:00 AM	LT1	LT1	
5-7-2024 12:10:00 PM	LT1	LT1	
5-21-2024 11:20:00 AM	LT1	LT1	
6-4-2024 11:40:00 AM	LT1	LT1	
6-17-2024 11:35:00 AM	LT1	LT1	
7-2-2024 9:05:00 AM	LT1	LT1	
7-15-2024 10:45:00 AM	LT1	LT1	
7-30-2024 10:55:00 AM	LT1	LT1	
8-13-2024 10:25:00 AM	LT1	LT1	
8-26-2024 11:40:00 AM	LT1	LT1	
9-9-2024 12:00:00 PM	LT1	LT1	
9-23-2024 11:12:00 AM	LT1	LT1	
10-7-2024 11:10:00 AM	LT1	LT1	
10-21-2024 11:10:00 AM	LT1	LT1	
11-5-2024 10:51:00 AM	LT1	LT1	
11-19-2024 10:35:00 AM	LT1	LT1	
12-2-2024 12:45:00 PM	LT1	LT1	
12-16-2024 10:40:00 AM	<u>LT1</u>	<u>LT1</u>	
<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

East Pioneer  
Sampling Station.

1-2-2024 12:00:00 PM	LT1	LT1	
1-16-2024 11:35:00 AM	QRWRT	QRWRT	
2-5-2024 11:40:00 AM	LT1	LT1	
2-20-2024 11:55:00 AM	LT1	LT1	
3-5-2024 10:35:00 AM	LT1	LT1	
3-18-2024 11:35:00 AM	LT1	LT1	
4-2-2024 9:30:00 AM	LT1	LT1	
4-15-2024 11:30:00 AM	LT1	LT1	
4-29-2024 11:55:00 AM	LT1	LT1	
5-13-2024 11:35:00 AM	LT1	LT1	
5-27-2024 9:30:00 AM	LT1	LT1	
6-11-2024 9:05:00 AM	LT1	LT1	
6-25-2024 10:20:00 AM	LT1	LT1	
7-8-2024 10:55:00 AM	LT1	LT1	
7-23-2024 10:30:00 AM	LT1	LT1	
8-6-2024 12:05:00 PM	LT1	LT1	
8-20-2024 8:55:00 AM	LT1	LT1	
9-3-2024 11:15:00 AM	LT1	LT1	
9-16-2024 8:30:00 AM	LT1	LT1	
10-1-2024 11:40:00 AM	LT1	LT1	
10-15-2024 12:10:00 PM	LT1	LT1	
10-29-2024 9:30:00 AM	LT1	LT1	
11-12-2024 11:50:00 AM	LT1	LT1	
12-10-2024 10:10:00 AM	<u>LT1</u>	<u>LT1</u>	
<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

Vimy Road Sampling

Station,

1-2-2024 12:15:00 PM	LT1	LT1	
2-5-2024 12:05:00 PM	LT1	LT1	
2-20-2024 12:05:00 PM	LT1	LT1	
3-5-2024 10:45:00 AM	LT1	LT1	
3-18-2024 11:20:00 AM	LT1	LT1	
4-2-2024 11:55:00 AM	LT1	LT1	
4-15-2024 11:50:00 AM	LT1	LT1	
4-29-2024 11:35:00 AM	LT1	LT1	
5-13-2024 11:45:00 AM	LT1	LT1	
5-27-2024 9:55:00 AM	LT1	LT1	
6-11-2024 8:30:00 AM	LT1	LT1	
6-25-2024 10:30:00 AM	LT1	LT1	
7-8-2024 11:05:00 AM	LT1	LT1	
7-23-2024 10:40:00 AM	LT1	LT1	
8-6-2024 12:15:00 PM	LT1	LT1	
8-20-2024 9:05:00 AM	LT1	LT1	
9-3-2024 11:20:00 AM	LT1	LT1	
9-16-2024 11:25:00 AM	LT1	LT1	
10-1-2024 11:50:00 AM	LT1	LT1	
10-15-2024 12:00:00 PM	LT1	LT1	
10-29-2024 9:45:00 AM	LT1	LT1	
11-12-2024 12:05:00 PM	LT1	LT1	
11-26-2024 1:05:00 PM	LT1	LT1	
12-10-2024 10:20:00 AM	<u>LT1</u>	<u>LT1</u>	
<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

Reservoir 1,

1-8-2024 9:15:00 AM	LT1	LT1	
2-20-2024 10:05:00	LT1	LT1	

AM		
2-26-2024 8:00:00	LT1	LT1
AM		
3-11-2024 10:30:00	LT1	LT1
AM		
3-25-2024 9:30:00	LT1	LT1
AM		
4-23-2024 11:45:00	LT1	LT1
AM		
5-7-2024 10:15:00	LT1	LT1
AM		
5-21-2024 10:50:00	LT1	LT1
AM		
6-3-2024 10:25:00	LT1	LT1
AM		
6-17-2024 9:00:00	LT1	LT1
AM		
7-2-2024 8:05:00	LT1	LT1
AM		
7-15-2024 8:50:00	LT1	LT1
AM		
7-29-2024 9:45:00	LT1	LT1
AM		
8-13-2024 8:45:00	LT1	LT1
AM		
8-26-2024 10:05:00	LT1	LT1
AM		
9-9-2024 9:25:00	LT1	LT1
AM		
9-23-2024 9:12:00	LT1	LT1
AM		
10-7-2024 9:10:00	LT1	LT1
AM		
10-22-2024 10:15:00	LT1	LT1
AM		
11-5-2024 10:32:00	LT1	LT1
AM		
11-19-2024 10:05:00	LT1	LT1
AM		
12-2-2024 10:05:00	LT1	LT1
AM		
12-16-2024 9:25:00	<u>LT1</u>	<u>LT1</u>
AM		
<b>Total Positive:</b>	<b>0</b>	<b>0</b>
		<b>0</b>

Reservoir 2

1-2-2024 9:40:00	LT1	LT1
AM		
2-5-2024 9:35:00	LT1	LT1
AM		
2-12-2024 11:00:00	LT1	LT1
AM		
3-5-2024 9:00:00	LT1	LT1
AM		
3-18-2024 9:40:00	LT1	LT1

AM		
4-2-2024 9:45:00	LT1	LT1
AM		
4-15-2024 9:50:00	LT1	LT1
AM		
4-29-2024 9:15:00	LT1	LT1
AM		
5-13-2024 9:30:00	LT1	LT1
AM		
5-27-2024 9:20:00	LT1	LT1
AM		
6-10-2024 9:35:00	LT1	LT1
AM		
6-25-2024 10:00:00	LT1	LT1
AM		
7-8-2024 9:20:00	LT1	LT1
AM		
7-22-2024 9:35:00	LT1	LT1
AM		
8-6-2024 9:35:00	LT1	LT1
AM		
8-19-2024 8:55:00	LT1	LT1
AM		
9-3-2024 9:10:00	LT1	LT1
AM		
9-16-2024 8:30:00	LT1	LT1
AM		
10-1-2024 9:45:00	LT1	LT1
AM		
10-15-2024 9:15:00	LT1	LT1
AM		
10-29-2024 8:47:00	LT1	LT1
AM		
11-12-2024 11:25:00	LT1	LT1
AM		
11-25-2024 11:50:00	LT1	LT1
AM		
12-9-2024 10:10:00	<u>LT1</u>	<u>LT1</u>
AM		
<b>Total Positive:</b>	<b>0</b>	<b>0</b>

0

**Result Values:**

**E - estimated**

**L - less than**

**G - greater than**

Samples that contain total coliform:	1	0.61% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/3	
Total number of samples:	165	

**Comments:**

Environmental Health Officer

Jan 14 2025

FOR FURTHER INFORMATION PLEASE CALL: Jessica Hibbs (604) 870-7900